

*BC HYDRO EXPERIENCE WITH PSEUDO MEASUREMENTS
IN STATE ESTIMATION*

Djordje Atanackovic
Grid Operations
BC Hydro

**IEEE PES General Meeting, July 27th, 2011, Detroit,
Michigan, U.S.A.**

Presented by
Raju VINNAKOTA, BC Hydro on behalf of Djordje

INTRODUCTION

- Network model characteristics
- Measurement model overview
- Load model overview
- Overview of BC Hydro state estimator implementation
- **Load allocation methodology**
- Impact on state estimator solution quality
- Utilization of branch pseudo measurements
- Conclusions

- Network model comprises 2500 buses, 386 generators, 1126 loads
- Includes detailed model of BC Hydro control areas and approximate models of BPA and TAU areas
- Voltage levels from 500kV down to 25kV and 12kV feeder heads
- Large portion of 60kv network is modeled in detail
- Presence of lines with high r/x ratio
- Customized HVDC model

- Redundant telemetry in 500kv and portions of 230kV network
- Unobservable areas in parts of 230kV, 138kv, 60kV and 25kV networks
- Large unobservable areas in external networks
- Large number of current measurements
- Significant number of summed measurements

- ZIP load model (constant impedance, constant current, constant power)
- Load lumped at low voltage buses of distribution transformers (60 kV, 25KV and 12KV)
- Loads not directly measured
- Most of the loads located in network areas that are unobservable or weakly observable
- Presence of loads that consume reactive power

- State estimation is executed in three steps
- Pre-se power flow
- State estimator (RTNET)
- Post-se power flow

- Pre-SE power flow is run with the objective to:
 - Provide better initial condition
 - Provide values for branch pseudo measurements
 - Determine the ratio for split of summed measurements over components
- Pre-SE power flow relies on the following inputs:
 - Real-time switch statuses
 - Real-time analog measurements of generator MW outputs and bus voltage magnitudes
 - Allocated MW and MVAR loads

- Post-SE power flow is run with the objective to:
 - Refine the solution after re-distribution of bus mismatches
 - Verify the feasibility of state estimator result
- Post-SE power flow relies on the following inputs:
 - State estimator solution
 - All controls are disabled in order to preserve the solution close to original state estimator result

- Each BC Hydro load is allocated in real-time before the execution of pre-SE power flow
- Load allocation factors are used to split the total BC Hydro control area load to individual loads
- Hourly schedule of load allocation factors (both MW and power factor) for regular week days plus holidays is assigned to each load in the area

- Total control area load is calculated by AGC in real-time in every AGC cycle (4 seconds) based on:
 - Real-time measurements of generator MW outputs and tie-lines
 - Total area MW loss calculated in previous state estimator run
- The calculation of load allocation factors is performed on the external server
- Hourly schedules for all loads for the entire week are uploaded to EMS every Monday at 10am
- State estimator processes the schedules in every run to allocate loads before pre-SE power flow executes

LOAD ALLOCATION METHODOLOGY

NETWORK_ONLINE_SEQUENCE_OLNETSEQ[EMS] FVEMS1A.BCTC.EMS (A) Page: 1 - Viewport A - FVEMS1B EMS

File Navigate HABITAT Applications EMP Applications Overviews Related Displays Analyst Displays Help

Network Online Sequence Contingencies

PRESE PF 27-May-2011 10:45:08

STATE EST. 27-May-2011 10:45:11

POSTSE PF 27-May-2011 10:45:16

TSAPM 27-May-2011 10:45:18

RTCA 27-May-2011 10:43:25

VVD 27-May-2011 10:43:27

QKNET

Sequence

Application	Task	Enable	Program Status	Last Completion
RTNET	COMPLETED LOSS CALCULATION			
	ESTIMATE	<input checked="" type="checkbox"/>	Sleeping	27-May-2011 10:45:16
	LOSSES	<input checked="" type="checkbox"/>	Sleeping	27-May-2011 10:45:16
TSAPM	TSAPM COMPLETED			
	TSAPM	<input checked="" type="checkbox"/>	Sleeping	27-May-2011 10:45:18
RTCA	WRITING DATABASES			
	CA	<input checked="" type="checkbox"/>	Active	27-May-2011 10:43:25
VVD	VVD COMPLETED			
	VVD	<input checked="" type="checkbox"/>	Pending	27-May-2011 10:43:27
RTVSA	VSA COMPLETED			
	VSAFILES	<input checked="" type="checkbox"/>	Pending	27-May-2011 10:41:37
RTTSA	TSA COMPLETED			
	TSAFILES	<input checked="" type="checkbox"/>	Pending	27-May-2011 10:41:37

Solution Quality

Item	Results
Total Unit MW Error	61.9
Total Tie Line MW Error	10.3
Solution Cost Index	6741.2
Data Availability %	81.6
Max MW Mismatch	39.4
Total Load Allocation Error (MW)	236.0
Total Negative Generation (MW)	-23.6

System Information

Company	BCH	Integrated Total System Losses...
Generation	7325 MW	Losses 388 MW
Load	7176 MW	Loss Ratio 5.4 %

TSA EXECUTION CONTROL

Contingency Analysis

VSA LIMITS

(To be commissioned)

RTVSA 2-D PLOT

Last Result: **Violations**

Show Violations **NING**

NORMALIZED RESIDUAL

MSSC

CONTINGENCY SOLUTION

STATE EST / NET APP OV

BUS MISMATCH LIST

VVD SOLUTION

NETWORK ONLINE SEQUENCE

ALARM VIOLATION

OPF LOSSMIN **(Watch)**

RTGEN/GEN_UNIT_STATUS

5/27/2011 10:45:29 AM

LOAD ALLOCATION METHODOLOGY

LOAD_RTNET[EMS] FVEMS1A.BCTC.EMS (D) Page:1 - Viewport D - FVEMS1B EMS

File Navigate HABITAT Applications EMP Applications Overviews Related Displays Analyst Displays Help

Network Load Summary

RTNET Last Solved: 27-May-2011 10:45:08 Voltage Dependency Band 1.000 RTNET REALTIME LOSSES CALC ED

Station Load	Company	Area	Remv	Dead	Open	Estimated MW	Estimated MVAR	Power Factor	Man	Model MW	Model MVAR	Measured MW	Measured MVAR	Allocation Factor	Load Area	MVAR Schedule	Enable ZIPMDL
UNS	BCH	BCH				4.5	0.9	0.98		4.5	0.9			4.0	UNS 5	UNS 5V	
UNSLD			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
VDK	BCH	BCH				0.7	0.8	0.65		0.7	0.8			0.6	VDK 4	VDK 4V	
VDKLOAD			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
WAH	BCH	BCH		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0.0	0.0	0.93		0.0	0.0			6.8	WAH 39	WAH 39V	
T2LD			<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>												
WAH	BCH	BCH		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	0.0	0.0	0.93		0.0	0.0			6.8	WAH 44	WAH 44V	
T5LD			<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>												
WAH	BCH	BCH				9.7	2.0	0.98		9.7	2.0			8.6	WAH 15	WAH 15V	
WAHLOAD			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
WAH	BCH	BCH			<input checked="" type="checkbox"/>	0.0	0.0	0.00		0.0	0.0			0.0	WAH 37	WAH 37V	
60-25			<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>												
WCF	BCH	BCH				0.3	0.0	0.99		0.3	0.0			0.3	WCF 3	WCF 3V	
WCFLOAD			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
WFR	BCH	BCH				4.0	1.6	0.93		4.0	1.6			3.5	WFR 2	WFR 2V	
WFRLOAD			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
WHY	BCH	BCH				51.4	13.5	0.97		53.0	13.3			46.9	WHY 9	WHY 9V	
WHYLOAD1			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
WHY	BCH	BCH				53.1	27.0	0.89		53.0	27.1			46.9	WHY 10	WHY 10V	
WHYLOAD2			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
WHY	BCH	BCH			<input checked="" type="checkbox"/>	0.0	0.0	0.00		0.0	0.0			0.0	WHY 24	WHY 24V	
STN			<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>												
WLT	BCH	BCH			<input checked="" type="checkbox"/>	0.0	0.0	0.93		0.0	0.0			6.8	WLT 33	WLT 33V	
T1LD			<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>												
WLT	BCH	BCH			<input checked="" type="checkbox"/>	0.0	0.0	0.93		0.0	0.0			6.8	WLT 35	WLT 35V	
T2LD			<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>												
WLT	BCH	BCH			<input checked="" type="checkbox"/>	0.0	0.0	0.00		0.0	0.0			0.0	WLT 31	WLT 31V	
2-60			<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>												
WRK	BCH	BCH			<input checked="" type="checkbox"/>	0.0	0.0	1.00		0.0	0.0			41.9	WRK 11	WRK 11V	
WRKLOAD			<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>												
WRK	BCH	BCH			<input checked="" type="checkbox"/>	0.0	0.0	0.00		0.0	0.0			0.0	WRK 69	WRK 69V	
60-25			<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>												
WTL	BCH	BCH				2.4	0.3	0.99		2.4	0.3			2.1	WTL 3	WTL 3V	
WTLLOAD			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
WTL	BCH	BCH				2.4	0.3	0.99		2.4	0.3			2.1	WTL 6	WTL 6V	
WTLLD2			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
HPS	BCH	BCH				4.2	0.2	0.00		4.2	0.2			4.0	HPS 8	HPS 8V	
HPSLD			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												

EMSDJA@FVEMS1A.BCTC.EMS:90 | (EMSDJA@QAEMS2B.BCTC.EMS:90) 5/27/2011 10:47:05 AM

LOAD ALLOCATION METHODOLOGY

LOADAREA_RTNET[EMS] FVEMS1A.BCTC.EMS (D) - Viewport D - FVEMS1B EMS

File Navigate HABITAT Applications EMP Applications Overviews Related Displays Analyst Displays Help

Network Load Summary

RTNET Last Solved: 27-May-2011 10:47:08

Load Area	Parent Area Load	Actual MW	Actual MVAR	Manual	Modeled MW	Base MW	Parent Fraction MW	Schedule	RTNET REALTIME LOSSES CALC ED	
									Reactive Individual	Reactive Cumulative
WIN_7	SIE	11.0	3.3	<input type="checkbox"/>	12.5	0.0	16.12	WIN_7	1.0000	1.0000
WLM_15	CI	6.7	40.6	<input type="checkbox"/>	3.7	0.0	5.42	WLM_15	1.0000	1.0000
WLM_16	CI	6.1	1.5	<input type="checkbox"/>	3.7	0.0	5.42	WLM_16	1.0000	1.0000
WLT_31	LM	0.0	0.0	<input type="checkbox"/>	0.0	0.0	0.00	WLT_31	1.0000	1.0000
WNR_2	NC	0.5	0.0	<input type="checkbox"/>	0.4	0.0	0.43	WNR_2	1.0000	1.0000
WNK_8	LM	0.0	0.0	<input type="checkbox"/>	0.3	0.0	0.46	WNK_8	1.0000	1.0000
WNK_9	LM	0.0	0.0	<input type="checkbox"/>	0.3	0.0	0.46	WNK_9	1.0000	1.0000
WOS_3	VI	0.0	0.0	<input type="checkbox"/>	2.7	0.0	2.08	WOS_3	1.0000	1.0000
WOL_5	CI	2.8	0.0	<input type="checkbox"/>	1.7	0.0	2.46	WOL_5	1.0000	1.0000
WRK_11	LM	0.0	0.0	<input type="checkbox"/>	31.6	0.0	41.91	WRK_11	1.0000	1.0000
WSN_76	CI	0.0	0.0	<input type="checkbox"/>	0.0	0.0	0.00	WSN_76	1.0000	1.0000
WSN_77	CI	0.0	0.0	<input type="checkbox"/>	0.0	0.0	0.00	WSN_77	1.0000	1.0000
WSSWKP_1	WKPL	35.4	12.9	<input type="checkbox"/>	25.0	0.0	31.57	WSSWKP_1	1.0000	1.0000
WTL_3	LM	2.4	0.3	<input type="checkbox"/>	1.6	0.0	2.09	WTL_3	1.0000	1.0000
WTL_6	LM	2.4	0.3	<input type="checkbox"/>	1.6	0.0	2.09	WTL_6	1.0000	1.0000
WWD_2	SIW	0.8	0.0	<input type="checkbox"/>	0.6	0.0	0.67	WWD_2	1.0000	1.0000
WWL_2	CI	1.9	0.4	<input type="checkbox"/>	1.1	0.0	1.65	WWL_2	1.0000	1.0000
WWL_5	CI	1.9	0.4	<input type="checkbox"/>	1.1	0.0	1.65	WWL_5	1.0000	1.0000
GMS_75	CI	2.3	0.7	<input type="checkbox"/>	1.4	0.0	2.00	GMS_75	1.0000	1.0000
REV_48	SIW	2.3	0.7	<input type="checkbox"/>	1.7	0.0	2.00	REV_48	1.0000	1.0000
POW_7	LM	0.0	0.0	<input type="checkbox"/>	0.0	0.0	0.00	POW_7	1.0000	1.0000
SEV_18	SIE	0.0	0.0	<input type="checkbox"/>	0.0	0.0	0.00	SEV_18	1.0000	1.0000
SLO_6	CI	9.7	6.3	<input type="checkbox"/>	6.7	0.0	9.76	SLO_6	1.0000	1.0000
VIT_111	VI	0.0	0.0	<input type="checkbox"/>	0.0	0.0	0.00	VIT_111	1.0000	1.0000
VIT_112	VI	0.0	0.0	<input type="checkbox"/>	0.0	0.0	0.00	VIT_112	1.0000	1.0000
OFD_16	NC	0.0	-0.0	<input type="checkbox"/>	0.0	0.0	0.00	OFD_16	1.0000	1.0000
OFD_17	NC	0.0	0.0	<input type="checkbox"/>	0.0	0.0	0.00	OFD_17	1.0000	1.0000
HRD_9	LM	45.9	13.4	<input type="checkbox"/>	30.0	0.0	39.78	HRD_9	1.0000	1.0000

▲ EMSDJA@FVEMS1A.BCTC.EMS:90 | (EMSDJA@QAEMS2B.BCTC.EMS:90) 5/27/2011 10:47:49 AM

LOAD ALLOCATION METHODOLOGY

LDAREA_SCHEDULES_RTNET[EMS] FVEMS1A.BCTC.EMS(D) page:542 - Viewport D - FVEMS1B EMS

File Navigate HABITAT Applications EMP Applications Overviews Related Displays Analyst Displays Help

Network Schedules

RTNET Last Solved: 27-May-2011 10:47:08

LDAREA Schedules	Step	Base MW	Parent Fraction MW	Time	Day Segment	Time Set
WRK_11	<input checked="" type="checkbox"/>	0.00	41.91			GLMEBCTC
		0.00	39.49	9 : 0	SU	
		0.00	41.09	10 : 0	SU	
		0.00	41.10	11 : 0	SU	
		0.00	41.55	12 : 0	SU	
		0.00	41.21	13 : 0	SU	
		0.00	40.64	14 : 0	SU	
		0.00	40.16	15 : 0	SU	
		0.00	39.21	16 : 0	SU	
		0.00	40.47	17 : 0	SU	
		0.00	43.07	18 : 0	SU	
		0.00	44.69	19 : 0	SU	
		0.00	43.71	20 : 0	SU	
		0.00	42.27	21 : 0	SU	
		0.00	44.76	22 : 0	SU	
		0.00	44.62	23 : 0	SU	
		0.00	38.82	0 : 0	MN	
		0.00	32.71	1 : 0	MN	
		0.00	29.10	2 : 0	MN	
		0.00	27.26	3 : 0	MN	
		0.00	26.25	4 : 0	MN	
		0.00	25.99	5 : 0	MN	
		0.00	26.92	6 : 0	MN	
		0.00	28.67	7 : 0	MN	
		0.00	33.66	8 : 0	MN	
		0.00	39.83	9 : 0	MN	


EMSDJA@FVEMS1A.BCTC.EMS:90 | EMSDJA@QAEMS2B.BCTC.EMS:90

5/27/2011 10:48:30 AM

- The calculation of load allocation factors is based on the following inputs:
 - Real-time data (MW, MVAR, Amps and KV) archived in PI
 - Load curves for each load that are based on historical information collected from billing department or from real-time (PI)
 - Grouping of loads and measurements into network pockets
- Filtering and smoothing techniques are used to process the input data, eliminate and substitute for bad data and determine the value of MW allocation factor and power factor for each load at a given hour

- The calculation algorithm based on the concept of network pockets
- The entire BC Hydro network is broken into network pockets (super buses) that group loads and adjacent real-time measurements
- The grouping is performed to create the smallest network pockets that can be observed by valid real-time measurements
- Ideally, the smallest network pocket would consist of a single load with direct MW and MVAR measurements

- Network pockets are defined manually through in depth analysis. Friendly user interface is provided for network pocket definition
- The analysis would start with locating the loads and determining the closest MW and MVAR measurement pairs that can observe the loads
- In the absence of MW/MVAR measurement pairs the KV and Amps measurements located at the same spot could also be used to observe a network pocket
- An approximate but sufficiently accurate approach is used to convert KV and Amps measurements into the equivalent MW/MVAR pairs



- Archived values of real-time measurements used to observe network pockets are retrieved from PI
- If archived values are found invalid for the particular day and time interval, the smoothing technique is applied to interpolate the values of adjacent intervals.
- The algebraic sum of a network pocket measurements is calculated. This sum is distributed over loads that are part of the network pocket.
- Distribution is performed using load curves that are determined through a series of filtering processes applied on historical data (LCF) or, when available, direct real-time data (PI) archived for each load

- Improves the quality of pseudo measurements (loads)
- Improves the quality of real-time load model
- Improves the quality of pre-SE power flow solution
- Significantly improves quality of load allocation (load allocation error quality index was reduced by 30%)
- Improves the total cost function
- Sets stage for better tuning – further reduction of bus mismatches (MW, MVAR)

- Load allocation error improved by 30%
- Cost function improved by 10%
- Total bus MW mismatch improved by 10%
- Pre-SE power flow robustness improved by 4%
(convergence rate went up from 93% to 97%)

- MW and MVAR flow measurements can be placed in branches (lines, transformers)
- Power flow calculated by pre-SE provides values for pseudo MW and MVAR
- Used to enforce branch flows in lines adjacent to generator buses
- Increases solution robustness

- More accurate load allocation improves significantly the quality of pseudo measurements
- Improves state estimator solution quality indices
- Sets stage for better state estimator tuning aimed at further reduction of bus mismatches
- Increases robustness of state estimator and related pre and post-SE power flows
- Has positive impact on other advanced applications such as real-time voltage stability analysis
- Requires regular maintenance process

QUESTIONS ?

Contact : djordje.atanackovic@bchydro.com